



Emergency Lighting Certification Form

FRM-003
Date:1/1/17
Mod:1/13/19

Approved by:
RWM

Please fill out all relevant portions of this form:

Business Name: _____

Address: _____

Business Phone: _____

Confirm emergency lighting for the following:

<input type="checkbox"/>	Aisles & unenclosed egress stairways in rooms and spaces requiring 2 or more means of egress.	<input type="checkbox"/>	Corridors, interior exit stairways & ramps & exit passageways in buildings required to have 2 or more exits.
<input type="checkbox"/>	Exterior egress components at other than their levels of discharge until exit discharge are complete.	<input type="checkbox"/>	Interior exit discharge elements in buildings required to have 2 or more exits.
<input type="checkbox"/>	Exterior landings for exit discharge doorways in buildings required to have 2 or more exits.	<input type="checkbox"/>	Additionally, ensure the following rooms have an emergency electrical system:
<input type="checkbox"/>	Electrical equipment rooms	<input type="checkbox"/>	Fire command centers
<input type="checkbox"/>	Fire pump rooms	<input type="checkbox"/>	Generator rooms
<input type="checkbox"/>	Generator rooms		

Notes (Per the California Fire Code):

- Emergency power system shall provide power for not less than 90 minutes
- The installation of the emergency power system shall be as per Section 604.
- 1008.3.5 Emergency lighting facilities shall be arranged to provide initial illumination that is at least an average of 1 foot candle (11 lux) and a minimum at any point of 0.1 foot candle (1 lux) measured along the path of egress at floor level. Illumination levels shall be permitted to decline to 0.6 foot candle (6 lux) average and a minimum at any point of 0.1 foot candle (1 lux) at any point of 0.06 foot candle (0.6 lux) at the end of duration. A maximum to minimum illumination uniformity ratio of 40 to 1 shall not be exceeded.

I certify under penalty of perjury that the company I represent has tested the emergency lighting at the above listed address DOES DOES NOT meet all applicable codes and standards

Name: _____ Title: _____

Company: _____

License #: _____ License Type: _____

Permit #: _____ Test Date: _____

Signature: _____ Date: _____